



নর্থ-ওয়েস্ট পাওয়ার জেনারেশন কোং লিঃ
North-West Power Generation Co. Ltd.
 ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018 Certified
 (An Enterprise of Bangladesh Power Development Board).

খুলনা ২২৫ মেঃওঃ
 সিসিপিপি
 গোয়ালপাড়া, খুলনা
 ফোনঃ০৪১-৭৬৩৭৭৩

তত্ত্বাবধায়ক প্রকৌশলী, খুলনা ২২৫ মেঃওঃ কম্বাইন্ড সাইকেল বিদ্যুৎ কেন্দ্র, নর্থ-ওয়েস্ট পাওয়ার জেনারেশন কোম্পানি লিমিটেডের Key Performance Indicator Targets এবং Weight Factors (অর্থ বছর ২০১৯-২০):

SN	Performance Indicator (PI)	Target Unit	Weight	100%	90%	80%	70%
01	Plant Factor	%	8	≥25	24	23	22
02	Availability Factor	%	17	≥95	94	93	92
03	Auxiliary Consumption	%	8	≤4.7	4.73	4.77	4.8
04	Heat Rate	KJ/KWh	8	≤8,745	8795	8845	8895
05	Availability of Fuel	Continuous Running	8	9	8	7	6
		Long Shutdown		4	3.5	3	2.5
06	Annual Training hour per Employee	hours	4	≥70	68	66	64
07	Availability of chemical	Avg. Stock (% of the storage capacity)	3	≥60	58	56	54
08	Availability of demi-water with proper quality (demi-water quality parameter shall be recorded)	Avg. Stock (% of the storage capacity)	3	≥80	78	76	74
09	E-GP Tendering	0% of local tender	4	100	98	96	94
10	Conducting financial audit & settlement of dispute within 3 months	%	3	100	98	96	94
11	Conducting ISO audit & settlement of dispute within 3 months	%	3	100	98	96	94
12	Finalization of Annual Maintenance Program	Date	2	22 th June of previous FY	25 th June	28 th June	30 th June
13	Execution of Maintenance Program(% of activities performed on schedule)	%	4	100	90	80	70
14	Preparation of APP and Budget for O&M of the plant	Date	2	22 th June of previous FY	25 th June	28 th June	30 th June

Handwritten signature/initials

Handwritten signature/initials

15	Procurement of goods & services as per APP of the power plant (% of budget allocation)	%	4	100	95	90	85
16	All administrative, financial allied works	%	2	100	90	80	70
17	All communication with external organization for smooth operation of the power Plant	%	2	100	90	80	70
18	Perform other administrative & technical job as and when assigned by higher authority.	%	0	100	90	80	70
Total =			85				

Amrazid
20/06/2019

তত্ত্বাবধায়ক প্রকৌশলী

খুলনা ২২৫ মেঃওঃ কস্মাইন্ড সাইকেল বিদ্যুৎ কেন্দ্র
নর্থ-ওয়েস্ট পাওয়ার জেনারেশন কোম্পানি লিমিটেড

[Signature]
20/6/19

প্রধান প্রকৌশলী (প্লান্ট ম্যানেজার)

খুলনা ২২৫ মেঃওঃ কস্মাইন্ড সাইকেল বিদ্যুৎ কেন্দ্র
নর্থ-ওয়েস্ট পাওয়ার জেনারেশন কোম্পানি লিমিটেড