



নর্থ-ওয়েস্ট পাওয়ার জেনারেশন কোম্পানি লিঃ

North-West Power Generation Company Ltd.
ISO 9001: 2015, ISO 14001: 2015 & ISO 45001:2018 Certified
(An Enterprise of Bangladesh Power Development Board)


ইউটিসি ভবন
(৩য় ও ৪র্থ তলা)
৮নং কাওরানবাজার
ঢাকা-১২১৫।
ফোনঃ ৯১৪৫২৯১-৯২

(সংযুক্তি-২)


প্ল্যান্ট ম্যানেজার (তত্ত্বাবধায়ক প্রকৌশলী), সিরাজগঞ্জ ২২৫ মেঃওঃ কন্সাইন্ড সাইকেল বিদ্যুৎ কেন্দ্র (২য় ইউনিট), নর্থ-ওয়েস্ট পাওয়ার জেনারেশন কোম্পানি লিমিটেড-এর Key Performance Indicator Targets এবং Weight Factors (অর্থ বছর ২০১৯-২০)ঃ

SN	Performance Indicator (PI)	Target Unit	Weight	100%	90%	80%	70%
01	Plant Factor	%	10	≥ 63	62	61	60
02	Availability Factor	%	20	≥ 92	91	90	88
03	Auxilliary Consumption	%	8	≤ 4.28	4.30	4.34	4.37
04	Heat Rate	kJ/KWh	8	≤ 7700	7750	7800	7850
05	Annual Training Hour per Employee	hours	4	≥ 65	62	60	57
06	Availability of Chemical	Avg. Stock (% of the storage capacity)	3	≥ 55	53	51	49
07	Availability of demi-water with proper quality (demi-water quality parameter shall be recorded)	Avg. Stock (% of the storage capacity)	3	≥ 80	78	76	74
08	E-GP Tendering	% of Local tenders	4	100	98	96	94
09	Conducting financial audit & settlement of dispute within 2 months	%	3	100	98	96	94
10	Conducting ISO audit & settlement of dispute within 3 months	%	3	100	98	96	94
11	Finalization of Annual Maintenance Program	Date	2	22 nd June of previous FY	25 th June	28 th June	30 th June
12	Execution of Maintenance Program (% of activities performed on schedule)	%	4	100	90	80	70
13	Preparation of APP and Budget for O&M of the plant	Date	2	22 nd June of previous FY	25 th June	28 th June	30 th June
14	Procurement of goods and services as per APP of the Power Plant (% of budget allocation)	%	4	100	95	90	85
15	All administrative, financial allied works	%	2	100	90	80	70

SN	Performance Indicator (PI)	Target Unit	Weight	100%	90%	80%	70%
16	All communication with external organisation for smooth operation of the Power Plant	%	2	100	90	80	70
17	Perform other administrative & technical job as and when assigned by higher authority.	%	3	100	90	80	70
Total			85				


20/06/19

প্র্যান্ট ম্যানেজার (ভ্রাবধায়ক প্রকৌশলী)
সিরাজগঞ্জ ২২৫ মেঃওঃ কঃ সাঃ বিদ্যুৎ কেন্দ্র (২য় ইউনিট)
নর্থ-ওয়েস্ট পাওয়ার জেনারেশন কোম্পানি লিমিটেড


20.6.19

প্রধান প্রকৌশলী
সিরাজগঞ্জ বিদ্যুৎ কেন্দ্র
নর্থ-ওয়েস্ট পাওয়ার জেনারেশন কোম্পানি লিমিটেড