



নর্থ-ওয়েস্ট পাওয়ার জেনারেশন কোম্পানি লিঃ  
North-West Power Generation Company Ltd.  
ISO 9001: 2015, ISO 14001: 2015 & ISO 45001:2018 Certified  
(An Enterprise of Bangladesh Power Development Board)

ইউটিসি ভবন  
(৩য় ও ৪র্থ তলা)  
৮নং কাওরানবাজার  
ঢাকা-১২১৫।  
ফোনঃ ৯১৪৫২৯১-৯২

(সংযুক্তি-২)

প্ল্যান্ট ম্যানেজার (তত্ত্বাবধায়ক প্রকৌশলী), সিরাজগঞ্জ ২২৫ মেঃওঃ কন্সাইন্ড সাইকেল বিদ্যুৎ কেন্দ্র (৩য় ইউনিট), নর্থ-ওয়েস্ট পাওয়ার জেনারেশন কোম্পানি লিমিটেড-এর Key Performance Indicator Targets এবং Weight Factors (অর্থ বছর ২০১৯-২০)ঃ

SN	Performance Indicator (PI)	Target Unit	Weight	100%	90%	80%	70%
01	Plant Factor	%	10	≥ 64	63	62	61
02	Availability Factor	%	20	≥ 92	91	90	88
03	Auxilliary Consumption	%	10	≤ 4.25	4.28	4.30	4.34
04	Heat Rate	kJ/KWh	8	≤ 7700	7750	7800	7850
05	Annual Training Hour per Employee	hours	4	≥ 65	62	60	57
06	E-GP Tendering	% of Local tenders	4	100	98	96	94
07	Conducting financial audit & settlement of dispute within 2 months	%	3	100	98	96	94
08	Conducting ISO audit & settlement of dispute within 3 months	%	3	100	98	96	94
09	Finalization of Annual Maintenance Program	Date	3	22 <sup>nd</sup> June of previous FY	25 <sup>th</sup> June	28 <sup>th</sup> June	30 <sup>th</sup> June
10	Execution of Maintenance Program (% of activities performed on schedule)	%	6	100	90	80	70
11	Preparation of APP and Budget for O&M of the plant	Date	3	22 <sup>nd</sup> June of previous FY	25 <sup>th</sup> June	28 <sup>th</sup> June	30 <sup>th</sup> June
12	Procurement of goods and services as per APP of the Power Plant (% of budget allocation)	%	4	100	95	90	85
13	All administrative, financial allied works	%	2	100	90	80	70

SN	Performance Indicator (PI)	Target Unit	Weight	100%	90%	80%	70%
14	All communication with external organisation for smooth operation of the Power Plant	%	2	100	90	80	70
15	Perform other administrative & technical job as and when assigned by higher authority.	%	3	100	90	80	70
Total			85				

*Hayomal*  
20.06.2019.

প্ল্যান্ট ম্যানেজার (উদ্ভাবনায়ক প্রকৌশলী)  
সিরাজগঞ্জ ২২৫ মেঃওঃ কঃ সাঃ বিদ্যুৎ কেন্দ্র (৩য় ইউনিট)  
নর্থ-ওয়েস্ট পাওয়ার জেনারেশন কোম্পানি লিমিটেড

*সৈয়দুল হক*  
20.6.19

প্রধান প্রকৌশলী  
সিরাজগঞ্জ বিদ্যুৎ কেন্দ্র  
নর্থ-ওয়েস্ট পাওয়ার জেনারেশন কোম্পানি লিমিটেড